



What Does a Good Electrical Maintenance Program Look Like?

Gary Walls: President
Utilities Instrumentation Service



References

Coache, Christopher D. *NFPA 70E: Standard for Electrical Safety in the Workplace*. NFPA, 2017.

Hickman, Palmer, and Tim Crnko. *Electrical Safety Related Work Practices: Based on NFPA 70E 2018 Edition*. Alliance, 2018.

NFPA 70B: Recommended Practice for Electrical Equipment Maintenance. National Fire Protection Association, 2015.

Richard, Melissa. *Standard for Acceptance Testing Specifications for Electrical Power Equipment and Systems*. InterNational Electrical Testing Association, 2017.

Tanz, Jayne. *Standard for Maintenance Testing Specifications for Electrical Power Equipment and Systems*. InterNational Electrical Testing Association (NETA), 2015.

Goals Today



What is Maintenance?



Why have an Electrical Maintenance Program (EMP)?



Electrical preventative maintenance program outline



Questions

What is Maintenance?



- ▶ Auto Preventative Maintenance
 - ▶ Oil
 - ▶ Filters
 - ▶ Tires
 - ▶ Wiper Blades
 - ▶ Washing
 - ▶ Windows
 - ▶ Seats / Floor



Electrical Systems

- ▶ Switchgear and Switchboard Assemblies
- ▶ Transformers
- ▶ Cables
- ▶ Switches
- ▶ Circuit Breakers
- ▶ Protective Relays
- ▶ Instrument Transformers

Electrical Systems Continued...

- ▶ Metering Devices
- ▶ Grounding Systems
- ▶ Motor Control Centers
- ▶ Direct - Current Systems, Batteries
- ▶ Capacitors and Reactors
- ▶ Emergency Systems, Engine Generator

Why?

Safety

Reliability

Insurance

Maintenance Considerations

- Example : Abnormal Environmental Conditions Require More Maintenance



Courtesy of Eaton Corporation

- “Silver whiskers” are caused by a contaminated environment, and the lack of maintenance led to control power transformer failure on this medium voltage switchgear.

Maintenance Considerations

- Example : Important to Verify Proper Operation of Electrical Equipment
- Lack of maintenance can lead to bus failure as dirt, moisture, and contaminants cause tracking.



Courtesy of Eaton Corporation

© 2015 NJATC














Maintenance Considerations

- ▶ Condition of Maintenance
 - ▶ Improper or lack of maintenance on an OCPD can lead to higher incident energy than the arc flash risk assessment determines
 - ▶ IEEE paper “*Prioritize Circuit Breaker and Protective Relay Maintenance Using Arc Flash Hazard Assessment*”
 - ▶ In the study of a specific industrial facility, if the closest upstream circuit breaker or relay did not operate and the next higher level upstream OCPD cleared the arcing fault, in approximately $\frac{2}{3}$ of the cases, the Electrical Worker would not have adequate arc rated PPE.

Maintenance Considerations

- OCPD Maintenance Can Affect Arc-Flash Hazard (continued)

22.6 kA Symmetrical
Available Fault Current
at 480 volts, 3-phase



What happens if...

Lack of maintenance causes the OCPD to clear in 30 cycles rather than 6 cycles?

The actual arc-flash hazard would be much greater than the calculated arc-flash hazard.

125 inches

29 cal/cm²



Arc Flash Hazard Analysis for This Panel
Incident Energy: **5.8** cal/cm² at 18 inches
AFPB: **47** inches

Maintenance Considerations

- ▶ The Value of Electrical Safety-Related Maintenance
 - ▶ *NFPA 70E* Scope includes addressing safety-related maintenance requirements
 - ▶ New *NFPA 70E* definition:
“**Maintenance, Condition of.** The state of the electrical equipment considering the manufacturers’ instructions, manufacturers’ recommendations, and applicable industry codes, standards, and recommended practices.”

ELECTRICAL KEYES NOTES: \odot

1. EXISTING MAIN MCC, SEE SHEET 03.
2. NEW 200A, 1-POLE, SERVICE ENTRANCE MAIN RATED CIRCUIT BREAKER.
3. (2) SETS OF 4-#600, 1-#1 GND IN 3" C.
4. NEW 200A, DELAYED TRANSITION, BY-PASS ISOLATION TRANSFER SWITCH.
5. 3-#10, 1-#10 GND IN 1" C.
6. 2-#14 (OVERTEMP), 2-#14 (LEAK SEAL), 1-#14 GND IN 3/4" C, TYPICAL OF (4).
7. 3-#12, 1-#12 GND IN 3/4" C, TYPICAL OF (4).
8. 30A, NON-FUSED, NEMA 4X DISCONNECT.
9. 8"x8"x4" NEMA 4X TERMINAL BOX WITH BACK PLATE AND TERMINAL BLOCK FOR CABLE TRANSITION.
10. SENSOR CABLE WITH MIXER MOTOR, TYPICAL OF (4).
11. POWER CORD, FURNISHED WITH MIXER, INSTALLED BY CONTRACTOR, TYPICAL OF (4).
12. SCADA MONITORING SEE SCADA AND AREA SPECIFIC DRAWING.
13. 3-#12, 1-#12 GND IN 3/4" C.
14. 2-#2/0 RHHW-2, 1-#1 GND IN 2" C.
15. 200A, NON-FUSED, NEMA 4X DISCONNECT.
16. EXISTING 3000V OHSW GENSET.
17. EXISTING NEMA GENERATOR BREAKER.
18. 3-#2 RHHW-2, 1-#1 GND IN 1-1/4" C.
19. 4-#10, 1-#10 GND IN 1-1/4" C.
20. 2-#14 (OVERTEMP), 2-#14 (LEAK SEAL), 1-#14 GND IN 3/4" C, TYPICAL OF (3).
21. 3-#12, 1-#12 GND IN 3/4" C, TYPICAL OF (2).
22. SENSOR CABLE, TYPICAL OF (2).
23. POWER CORD, FURNISHED WITH MIXER, INSTALLED BY CONTRACTOR, TYPICAL OF (2).
24. NEW EMERGENCY ISOLATION, MOUNT REMOTE FROM GENSET ON EQUIPMENT RACK.
25. (2) SETS OF 4-#600 CU IN 3" C, WITH (4) SPARE 3" CONDUITS, OR (6) SETS OF 4-#600 AL, 1-#250 CU GND IN 3-1/2" C, WITH (4) SPARE 3" CONDUITS.
26. (2) SETS OF 4-#600 CU, 1-#250 CU GND IN 3-1/2" C, OR (2) SETS OF 4-#600 AL, 1-#250 CU GND IN 3-1/2" C.
27. (2) SETS OF 4-#600 CU, 1-#1/0 CU GND IN 3-1/2" C, OR (4) SETS OF 4-#600 AL, 1-#1/0 CU GND IN 2-1/2" C.
28. 2-#10 CU, 1-#10 CU GND IN 1" C, GENERATOR INTIMATION CIRCUIT.
29. 2-#14 CU, 1-#14 CU GND IN 3/4" C.
30. CONTROL PANEL SUPPLIED WITH EQUIPMENT, CONTRACTOR TO COMPLETE ALL CONNECTIONS.
31. 2-#14 ATS/STATUS, 1-#14 GND, TO SLOWLY CONTROL PANEL.
32. 4-#600 CU, 1-#3 CU GND IN 4" C.
33. 60A, NON-FUSED, NEMA 4X DISCONNECT.
34. 3-#8 CU, 1-#8 CU GND IN 1" C.
35. 4-#1 CU, 1-#1 CU GND IN 1-1/2" C.
36. 3-#1/8 CU, 1-#1/8 CU GND IN 2" C.
37. 3-#8 CU, 1-#8 CU GND IN 1" C.
38. 3-#1 CU, #1-4 CU GND IN 1-1/2" C.
39. #1/2 BARE CU BONDED TO (2) 3/4"x3/4" COPPER CLAD GROUND ROD, SEPARATED BY 15' MINIMUM, SEE GROUNDING DETAIL.
40. (2) 4" PVC, SEE SITE DRAWING.
41. 5% IRO REACTOR - NYS, PL SERIES, NEMA 1 ENCLOSURE.
42. 2% IRO REACTOR - NYS, PL SERIES, NEMA 1 ENCLOSURE.
43. 3-#1, 1-#1 GND IN 1" C.
44. GROUNDING ELECTRODE, #8 CU IN 1" C, SEE GROUNDING DETAIL.
45. NEMA 4X 500V, 1, FUSED, COMBINATION MOTOR STARTER, WITH HAND-OFF SWITCH, PUSH TO TEST LED LAMP, GREEN-"ON", RED-"OFF", WITH ELECTROMAGNETIC OVERLOADS, 120V CONTROL POWER TRANSFORMER.
46. 2-#12, 1-#12 GND IN 3/4" C.
47. 3-#8, 1-#8 GND IN 3/4" C.
48. FURNISH & INSTALL (2) SPARE 100A BREAKERS.
49. FURNISH & INSTALL (4) SPARE 30A BREAKERS.



ELECTRICAL ONELINE
NOT TO SCALE

CONSULTANTS:

**SIMS DURKIN ASSOCIATES
ENGINEERING COMPANY**

1515 COUNTRY CLUB ROAD
INDIANAPOLIS, INDIANA 46134
317-509-6055 (FAX) 317-522-4138
JIM@SIMSDURKIN.COM
WEB: SIMS-DURKIN.COM

REVISIONS:	
DATE	DESCRIPTION

APPROVED BY:

THIS DRAWING AND THE IDEAS, DESIGN AND CONCEPTS CONTAINED HEREIN ARE THE EXCLUSIVE INTELLECTUAL PROPERTY OF TRIAD ASSOCIATES, INC. AND ARE NOT TO BE USED OR REPRODUCED, IN WHOLE OR IN PART, WITHOUT THE WRITTEN CONSENT OF TRIAD ASSOCIATES, INC.

TRIAD ASSOCIATES INC.
5836 LAWTON LOOP EAST DRIVE
INDIANAPOLIS, INDIANA 46216
PHONE: 317-377-8228 FAX: 317-377-6241

DISSEMINATION:

THE CITY OF KENDALLVILLE
NOBLE COUNTY, INDIANA

DRWG FILE: WASTEWATER TREATMENT PLANT IMPROVEMENTS PROJECT ELECTRICAL ONELINE

DRW NUMBER: 210234	DESIGNED BY:
DATE AS NOTED:	CHECKED BY:
PLOT SCALE: 1=1	PAGE ONE
DRAWN BY: ASD	DATE: DEC. 2011

ISSUED BY: [Signature]
ISSUING NUMBER: 211 - ELECTRICAL ONELINE

SET NO.

E11

Electrical Systems

- ▶ Switchgear and Switchboard Assemblies
- ▶ Transformers
- ▶ Cables
- ▶ Switches
- ▶ Circuit Breakers
- ▶ Protective Relays
- ▶ Instrument Transformers

Electrical Systems Continued...

- ▶ Metering Devices
- ▶ Grounding Systems
- ▶ Motor Control Centers
- ▶ Direct - Current Systems, Batteries
- ▶ Capacitors and Reactors
- ▶ Emergency Systems, Engine Generator

EMP Outline

- ▶ System Designs
- ▶ Acceptance & Commissioning Testing
- ▶ EMP
 - ▶ Energized Maintenance
 - ▶ Outage Maintenance

Main Parts of an EMP Program

- ▶ Responsible and Qualified Personnel
- ▶ Survey and analysis of electrical equipment and systems to determine maintenance requirements and priorities
- ▶ Programmed routine inspections and suitable tests
- ▶ Accurate analysis of inspection and test reports so that proper corrective measures can be prescribed
- ▶ Performance of necessary work
- ▶ Concise but complete records

Frequency of Maintenance Tests

- ▶ NETA recognizes that the ideal maintenance program is reliability-based, unique to each plant and to each piece of equipment. In the absence of this information and in response to requests for a maintenance timetable, NETA's Standards Review Council presents the following time-based maintenance schedule and matrix.
- ▶ One should contact a NETA Accredited Testing Company for a reliability-based evaluation.
- ▶ The following matrix is to be used in conjunction with Appendix B, Inspections and Tests. Application of the matrix is recognized as a guide only.
- ▶ Specific condition, criticality, and reliability must be determined to correctly apply the matrix. Application of the matrix, along with the culmination of historical testing data and trending, should provide a quality electrical preventive maintenance program.

MAINTENANCE FREQUENCY MATRIX				
		EQUIPMENT CONDITION		
		POOR	AVERAGE	GOOD
EQUIPMENT REQUIREMENT	LOW	1.0	2.0	2.5
	MEDIUM	0.50	1.0	1.5
	HIGH	0.25	0.50	0.75

APPENDIX B

Frequency of Maintenance Tests (continued)

Inspections and Tests Frequency in Months (Multiply These Values by the Factor in the Maintenance Frequency Matrix)				
Section	Description	Visual	Visual & Mechanical	Visual & Mechanical & Electrical
7.1	Switchgear & Switchboard Assemblies	12	12	24
7.2	Transformers			
7.2.1.1	Small Dry-Type Transformers	2	12	36
7.2.1.2	Large Dry-Type Transformers	1	12	24
7.2.2	Liquid-Filled Transformers	1	12	24
	Sampling	–	–	12
7.3	Cables			
7.3.1	Low-Voltage, Low-Energy	–	–	–
7.3.2	Low-Voltage, 600-Volt Maximum	2	12	36
7.3.3	Medium- and High-Voltage	2	12	36
7.4	Metal-Enclosed Busways	2	12	24
	Infrared Only	–	–	12
7.5	Switches			
7.5.1.1	Air, Low-Voltage	2	12	36
7.5.1.2	Air, Medium-Voltage, Metal-Enclosed	–	12	24
7.5.1.3	Air, Medium- and High-Voltage Open	1	12	24
7.5.2	Oil, Medium-Voltage	1	12	24
7.5.3	Vacuum, Medium-Voltage	1	12	24
7.5.4	Medium-Voltage, SF ₆	1	12	24
7.5.5	Cutouts	12	24	24
7.6	Circuit Breakers			
7.6.1.1	Air, Insulated-Case/Molded-Case	1	12	36
7.6.1.2	Air, Low-Voltage Power	1	12	36
7.6.1.3	Air, Medium-Voltage	1	12	36
7.6.2	Oil, Medium-Voltage	1	12	36
	Sampling	–	–	12
7.6.2	Oil, High-Voltage	1	12	12
	Sampling	–	–	12
7.6.3	Vacuum, Medium-Voltage	1	12	24
7.6.4	SF ₆	1	12	12
7.7	Circuit Switchers	1	12	12
7.8	Network Protectors	12	12	24



Annex I Maintenance Intervals

This annex is not a part of the recommendations of this NFPA document but is included for informational purposes only.

I.1 Introduction. This annex provides, in Table I.1, an initial guideline for maintenance intervals for equipment. It should be stressed that environmental or operating conditions of a specific installation should be considered and might dictate a different frequency of maintenance than suggested in this annex (*see* 8.2.5). Chapter 22 and Annex H deal specifically with

the maintenance of equipment that, by nature of its application, necessitates long intervals between shutdowns. It should be noted that maintenance, inspection, and test methods for equipment that can operate for long periods are essentially the same as for equipment that might be shut down frequently. However, the recommended work should be performed with more care and diligence to obtain the desired reliability for service to loads that can operate continuously for months or years.

Table I.1 Interval Guidelines

Item/Equipment	Task/Function	Interval	Reference	
Substations (Outdoor)	Infrared scanning	Annually	21.17	
	Insulators	Visual inspection	4–6 months	9.1.2.1
		Corona detection	4–6 months	9.1.2.2
Conductors	Electrical tests	As indicated by other PM	21.9	
	Visual inspection of connections	4–6 months	9.1.3	
	Check connections for tightness	As indicated by other PM	9.1.3	
Air-disconnecting switches	Visual inspection	4–6 months	9.1.4.2	
	Operation check	Annually	9.1.4.3	
	Contact inspection	Annually	9.1.4.3	
Grounding equipment	Visual inspection	Annually	9.1.5	
	Check connections for tightness	1–2 years	9.1.5	
	Electrical test	3 years	21.13, 21.14, 21.15	
Enclosures	Security/operational check	1–5 months	9.1.6	
Switchgear Assemblies	Infrared scanning	Annually	21.17	
Enclosures	Security/operational check		9.2.4	
	Outdoor	1–3 months		
	Indoor	6 months		
	Visual inspection		9.2.5 through 9.2.6.2	
	Outdoor	1–3 months		
Ventilation	Indoor	6 months		
	Visual inspection	1–3 months	9.2.8	
Space heaters	Operational check	Annually	9.2.7	
Insulation	Visual inspection/clean	Annually	9.2.10 through 9.2.14.3	
	Electrical tests	2 years	21.9	
Air Circuit Breakers, Medium Voltage				
Insulation	Visual inspection/clean	Annually	9.4.2	
	Electrical tests	3 years	21.9	
Contacts	Visual inspection/clean	Annually	9.4.3.1	
	Adjust	Annually	9.4.3.5	
	Electrical test	3 years	21.12, 21.16, 21.9.3.2	
Arc interrupters	Visual inspection/clean	Annually	9.4.4.3, 9.4.4.4	
	Electrical test	3 years	9.4.4.4	
	Air-puffer operational check	Annually	9.4.4.5	
Operating mechanism	Visual inspection	Annually	9.4.5.2	
	Operational check/adjustment	Annually	9.4.5.2	
Trip device circuit	Operational check	Annually	9.4.6.3	
Air Circuit Breakers, Low Voltage	Visual inspection/clean/adjust	Annually	9.4, 21.9, 21.10.2.5	
	Electrical tests	3 years		
Vacuum Circuit Breaker	Visual inspection/clean/adjust	Annually	9.4	
	Contact checks/vacuum integrity	3 years	9.5.1, 9.5.2	
	Electrical tests	3 years	21.9, 21.10.2.5	



(continues)

Energized Maintenance

Infrared Scanning

Ultrasonic
Scanning

Oil Sampling



CUSTOMER _____ PAGE _____
 ADDRESS _____ JOB # _____
 USER _____
 OWNER REPRESENTATIVE _____ TELEPHONE _____
 DATE _____ TEMPERATURE _____ °F HUMIDITY _____ % EQPT. LOCATION _____
 SUBSTATION _____ POSITION _____

NAMEPLATE DATA


MANUFACTURER _____ SERIAL NO. _____
 SPECIFICATION NO. _____ TYPE _____ CLASS _____
 PHASE _____ TEMPERATURE RISE _____ °C IMPEDANCE _____ % B/L RATING _____ W/PRI _____ W/SEC _____
 COOLANT _____ CAPACITY _____ TOTAL WEIGHT _____
 WINDING POLARITY _____ WINDING MATERIAL _____ K FACTOR _____
 PRIMARY VOLTAGE _____ DELTA WYE RATED CURRENT _____ AMPERES
 SECONDARY VOLTAGE _____ DELTA WYE RATED CURRENT _____ AMPERES
 TAP VOLTAGES _____
 TAP CONNECTIONS _____
 TAP SETTING _____ VOLTS # FANS _____ TAP CHANGER: INTERNAL EXTERNAL DRY TYPE

GAUGES:

COOLANT TEMPERATURE _____ °C MAXIMUM TEMPERATURE _____ °C RESET TEMPERATURE GAUGE
 COOLANT LEVEL _____ PRESSURE VACUUM _____ # LDR COUNTER _____
 OTHER GAUGES _____

VISUAL INSPECTION:

BUSHINGS _____ SUPPORT INSULATORS _____ CONNECTIONS _____
 PAINT _____ RADATORS _____ FANS _____
 NO-LOAD TAP CHANGER _____ LEAKS _____
 FAN PUMP CONTROLS _____
 ADDITIONAL EQUIPMENT _____
 GROUND CONDUCTOR SIZE _____ AWG/GRE # NO. OF GROUND CONDUCTORS _____ GROUND CONDUCTOR CONDITION _____



POST TEST VOLTAGES

NO LOAD SECONDARY VOLTAGE			
X1 - X2	V	X0 - 0	V
X1 - X3	V	X0 - X1	V
X2 - X3	V	X0 - X2	V
		X0 - X3	V

COMMENTS: _____
 DEFICIENCIES: _____

ACCEPTABLE NON - ACCEPTABLE (THIS FORM IS NOT TO BE REPRODUCED EXCEPT IN FULL)



LOW VOLTAGE POWER CIRCUIT BREAKER TEST



CUSTOMER _____ PAGE _____
 ADDRESS _____ JOB # _____
 USER _____
 OWNER REPRESENTATIVE _____ TELEPHONE _____
 DATE _____ TEMPERATURE _____ °F HUMIDITY _____ % EQPT. LOCATION _____
 SUBSTATION _____ POSITION _____

MANUFACTURER _____ SN / SO NO. _____ FRAME SIZE(F) _____
 BREAKER TYPE _____ SENSOR TAPS _____ MOUNTING B.I. D.C.
 FUSE CAT. NO. _____ CUBICLE CODE _____ THERMAL MEMORY ON OFF
 TRIP UNIT TYPE _____ CATALOG NO. _____ ZONE INTU. TARGETS

DESCRIPTION	INSPECTED	CONDITION	CLEAN/LUBE
CUBICLE AND RACKING DEVICES	<input type="checkbox"/>		
CONTACT FINGERS	<input type="checkbox"/>		
LOADING AND ARcing CONTACTS	<input type="checkbox"/>		
OVERCURRENT DEV. BATTERY	<input type="checkbox"/>		

DESCRIPTION	INSPECTED	CONDITION	CLEAN/LUBE
ARC CHUTES	<input type="checkbox"/>		
AUXILIARY DEVICES	<input type="checkbox"/>		
GROUND CONNECTION	<input type="checkbox"/>		
LOAD CONDUCTOR NO. _____	Size _____	Cu <input type="radio"/>	Al <input type="radio"/>

SETTINGS AS FOUND
 LONG TIME PU _____ x _____ A = _____ A DELAY _____ PT IN OUT N/A
 RATING PLUG(R) _____ SHORT TIME PU _____ = _____ A DELAY _____ PT IN OUT N/A
 SENSOR TAP _____ INST. PU _____ = _____ A ON OFF
 GRD. FLT. 3W 4W GRD. FLT. PU _____ = _____ A ON OFF DELAY _____ PT IN OUT N/A

SETTINGS AS LEFT
 LONG TIME PU _____ x _____ A = _____ A DELAY _____ PT IN OUT N/A
 RATING PLUG(R) _____ SHORT TIME PU _____ = _____ A DELAY _____ PT IN OUT N/A
 SENSOR TAP _____ INST. PU _____ = _____ A ON OFF
 GRD. FLT. 3W 4W GRD. FLT. PU _____ = _____ A ON OFF DELAY _____ PT IN OUT N/A

TCG NO. _____

FUNCTION	TEST AMPERES	CURRENT MULTIPLE	TIME BAND		POLE 1		POLE 2		POLE 3	
			MINIMUM	MAXIMUM	AS FOUND (seconds)	AS LEFT (seconds)	AS FOUND (seconds)	AS LEFT (seconds)	AS FOUND (seconds)	AS LEFT (seconds)
INSTANTANEOUS										
SHORT TIME										
LONG TIME										
GROUND FAULT										

EQUIPMENT TEMPERATURE _____ °C TEMPERATURE CORRECTION FACTOR TO 20°C, TCF _____

INSULATION RESISTANCE	POLE 1 MΩ (P1-P2)		POLE 2 MΩ (P2-P3)		POLE 3 MΩ (P3-P4)		POLE RESISTANCE - MILLI-OHMS READING		
	READING	20°C	READING	20°C	READING	20°C	POLE 1	POLE 2	POLE 3
POLE TO POLE									
POLE TO FRAME									
LINE TO LOAD									

CONTROL WIRING		COUNTER READING BEGEND	
READING	20°C		


COMMENTS: _____
 DEFICIENCIES: _____
 ACCEPTABLE NON - ACCEPTABLE (THIS FORM IS NOT TO BE REPRODUCED EXCEPT IN FULL)

CUSTOMER _____ PAGE _____
 ADDRESS _____ JOB # _____
 USER _____
 OWNER REPRESENTATIVE _____ TELEPHONE _____
 DATE _____ TEMPERATURE _____ °F HUMIDITY _____ % EQPT. LOCATION _____
 SUBSTATION _____ POSITION _____

CABLE SOURCE _____ CABLE TERMINATION POINT _____
 OPERATING VOLTAGE _____ kV INSTALLED IN _____ LENGTH _____ ft
 MANUFACTURER _____ INSULATION TYPE _____ INSULATION THICKNESS _____ mil
 SIZE _____ kcmil NO. OF CONDUCTORS _____ CONDUCTOR MATERIAL _____
 RATED VOLTAGE _____ kV GROUNDED UNGROUNDED BELTED SHIELDED AGE _____

CONNECTED EQUIPMENT _____

TIME MINUTES	TEST VOLTAGE	PHASE A μ A	PHASE B μ A	PHASE C μ A
0.25				
0.50				
0.75				
1.00				
1.25				
1.50				
1.75				
2.00				
3.00				
4.00				
5.00				
6.00				
7.00				
8.00				
9.00				
10.00				
11.00				
12.00				
13.00				
14.00				
15.00				
16.00				
17.00				
18.00				
19.00				
20.00				
21.00				
22.00				
23.00				
24.00				
25.00				
DECAY TO 5KV, SECS				
SHIELD RESIST. OHMS				



COMMENTS: _____
 DEFICIENCIES: _____

ACCEPTABLE NON - ACCEPTABLE (THIS FORM IS NOT TO BE REPRODUCED EXCEPT IN FULL)

NOTES USED:

DATE _____ TEMPERATURE _____ °F HUMIDITY _____ % EQPT. LOCATION _____
 SUBSTATION _____ POSITION _____

Report Number: _____ Location: _____ Year of Mtg.: _____
 Bank & Phase: _____ WV Rating: _____
 Serial Number: _____ Breathing: _____
 Manufacturer: _____ Cooling: _____
 Equipment Type: _____ Fluid Type: _____

Sample Date:				
Laboratory No.:				
Container No.:				
Temperature:				

D1538	Moisture	(ppm)				
D971	Interfacial Tension	(dynes/cm)				
D974	Acid Number	(mg/KOH/g)				
D1500	Color Number					
D1524	Visual Examination					
D877	Dielectric BV	(kV)				
D1816	Dielectric BV	(kV)				
D924	Power Factor	(% @ 25 C)				
D924	Power Factor	(% @ 100 C)				
D2668	Oxidation Inhibitor	(%)				
D129	Specific Gravity					
D88	Viscosity	(cSt)				
D97	Pour Point	(°C)				
D92	Flash Point	(°C)				
D92	Fire Point	(°C)				
D1807	Refractive Index					
D1275	Corrosive Sulfur					

Insulating Fluid Diagnostics

	ASTM D3467	IEEE Group I	<6B	>6B<28B	>34B	IEEE Group II	IEEE Group III
Moisture:	35 max		35 min	25 max	20 max		
Interfacial Tension:	40 min		34 min	25 min	30 min	34 min	16 min
Acid Number:	0.03 max		0.2 max	0.2 max	0.1 max	0.2 max	0.5 max
Color Number:	0.5 max						
Visual Examination:	clear & bright						
Dielect. BV D877:	30 min		26 min	26 min	26 min		
Dielect. BV D1816:	30 min		23 min	25 min	26 min		
Power Factor @ 25 C:	0.05 max						
Power Factor @ 100 C:	0.90 max						
Oxidation Inhibitor:	0.3 max						
Specific Gravity:	0.91 max						
Viscosity @ 40 C:	66 max						
Pour Point:	-40 max						
Flash Point:	145 min						
Fire Point:							
Refractive Index:							
Corrosive Sulfur:	noncorrosive						
Comments:							

COMMENTS: _____
 DEFICIENCIES: _____

ACCEPTABLE NON - ACCEPTABLE (THIS FORM IS NOT TO BE REPRODUCED EXCEPT IN FULL)

Questions?

Gary Walls

C: 734-216-7229

O: 734-424-1200

E: gary.walls@uiscorp.com

website: www.uiscorp.com

